

# Recycled Water Permit Compliance Requirements

MCWD USER SUPERVISOR TRAINING

# Training Contents

1. Quarterly
2. Annually
3. Other

# Quarterly

- Self monitoring forms (online)
  - Copies of the completed quarterly self-monitoring forms shall be submitted on or before March 15th, June 15th, September 15th, and December 15th of each year
    - MCWD reserves the right to change the required frequency of monitoring as needed
  - Includes Backflow Prevention Device Visual Hazard Assessment at end of form
- Irrigation rates and total area recycled water was applied (email)
  - At minimum, must report quarterly
    - major changes → notify MCWD minimum 1 month in advance



# Training Contents

1. Quarterly
- 2. Annually**
3. Other

# Annually

- Reduced pressure backflow prevention device testing
  - With CA/NV AWWA certified Backflow Prevention Device Tester
  - The User Supervisor is responsible for coordinating
  - Records of tests are maintained for minimum three years
  - Test records must be provided to MCWD
- MCWD inspections
  - MCWD Operation Department will call to give minimum 2 days heads up
  - Minimum frequency is annual, may be more frequent
- User Supervisor Training
  - Test required, recommended to review online videos



# Training Contents

1. Quarterly
2. Annually
3. **Other**



# Other




- 4 year cross-connection shutdown test
  - Needs CA/NV certified Cross Connection Control Specialist
  - MCWD and appropriate agencies to be notified with the intent that all parties attend
  - Minimum 60 minutes



Please reach out to MCWD  
Engineering Department if you have  
any questions

Thanks for watching our training!



MCWD Recycled Water - Safe, sustainable,  
drought-proof solutions protecting our  
groundwater's future